

EFFECTIVE APRIL 1, 2011

CARBON MONOXIDE ALARMS REQUIRED
IN NEW RESIDENTIAL CONSTRUCTION

ORSC R326

Single station carbon monoxide alarms complying with UL 2034 or a household carbon monoxide detection system shall be located in each bedroom or within 15 feet outside of each bedroom door. Single station carbon monoxide alarms shall be battery operated or receive their primary power from the building wiring system, with battery back-up.

Existing dwellings – where a new carbon monoxide source is introduced or work requiring a structural permit occurs in existing dwellings, carbon monoxide alarms shall be provided in accordance with Section R315.1.